

NOTES:

UNDERCROSSING

ELEVATION - CROSSING INSTALLATION

- 1. DURING BACKFILL OPERATIONS, A SAFETY RED PLASTIC RIBBON SHALL BE LAID 12" TO 18" ABOVE THE UNDERGROUND CABLE IN BOTH SIDES OF THE DITCH THE ENTIRE WIDTH OF SSCGP'S RIGHT OF WAY.
- 2. ABOVE GROUND ELECTRICAL OR FIBER OPTIC LOCATION MARKER WILL BE INSTALLED AT EACH END OF RED CONCRETE.
- 3. ALL FOREIGN LINES TO BE ENCASED IN SCH. 40 STEEL (MINIMUM) OR SCH. 80 PLASTIC (MINIMUM) PIPE.
- 4. RED CONCRETE MAY BE REQUIRED.



STANDARD ENCROACHMENT DETAILS
FOR INSTALLATION OF ELECTRICAL OR FIBER OPTIC CABLE
CROSSING SSCGP'S PIPELINE

V							
		REV.	DATE	BY	DESCRIPTION	APP	SCALE: 1" = 1'-0"
DRAWN BY: GLS	DATE: 05-04-2004	3	02-27-2023	CNC	UPDATED NOTES	MGD	P.1.N.
CHECKED BY:	DATE:	1	11-05-2007	JAK	REPLACES STD. DWG. 005-090-A-0143	_	DWG. NO.
APPROVED BY: RDH	DATE: 05-28-2004	2	09-04-1014	MDR	ADDED NOTE 3		STD-ENC-X-EC